



CERT

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-6302BT0366**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Crane Limited Delta Road, GB- St. Helens WA9 2ED
<b>Distributor</b> <i>Vertreiber</i>	Crane Limited Delta Road, GB- St. Helens WA9 2ED
<b>Product Category</b> <i>Produktart</i>	valves for drinking water : pipe disconnecter type DB (6302)
<b>Product Description</b> <i>Produktbezeichnung</i>	pipe disconnecter type DB made of stainless steel for the drinking water installation
<b>Model</b> <i>Modell</i>	IAT 2561
<b>Test Reports</b> <i>Prüfberichte</i>	supplement test: SP 001/14 from 20.01.2014 (TZW) type testing: SP 005/08-SP 009/08 from 12.08.2008 (TZW) KTW testing: K-228200-13-Ko from 08.04.2013 (WHY) hygienic testing: W-237426k-13-SI from 27.11.2013 (WHY) KTW testing: KA 551/11 from 19.12.2011 (TZW) hygienic testing: MO 216/12 from 06.11.2012 (TZW)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW W 570-2 (01.01.2008) DIN EN 14452 (01.08.2005) BGA KTW (12.12.1985) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	12.08.2018 / 13-0383-WNA

70028-04-A-DE

20.05.2014 G/A-1/2

Date/ Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b> <b>Typ</b>	<b>Technical Data</b> <b>Technische Daten</b>	<b>Remarks</b> <b>Bemerkungen</b>
5001565ST	nominal pressure rating: PN 10 nominal diameter: 3/8"	
5001575ST; 5001635ST	nominal pressure rating: PN 10 nominal diameter: 1/2"	
5001585ST; 5001660ST	nominal pressure rating: PN 10 nominal diameter: 3/4"	

<b>Type Variation</b> <b>Ausführungsvariante</b>	<b>Explanations</b> <b>Erläuterungen</b>
5001565ST	nominal diameter: 3/8"; internal thread/external thread or external thread/internal thread
5001575ST	nominal diameter: 1/2"; external thread/external thread
5001585ST	nominal diameter: 3/4"; external thread/external thread
5001635ST	nominal diameter: 1/2"; internal thread/external thread
5001660ST	nominal diameter: 3/4"; internal thread/external thread

<b>Hints of Utilization / Remarks</b> <b>Verwendungshinweise / Bemerkungen</b>
acoustic group: II