



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6309BU0243

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Crane Limited Delta Road, GB- St. Helens WA9 2ED
Distributor <i>Vertreiber</i>	Crane Limited Delta Road, GB- St. Helens WA9 2ED
Product Category <i>Produktart</i>	valves for drinking water : pipe disconnecter type DC (6309)
Product Description <i>Produktbezeichnung</i>	pipe disconnecter type DC made of stainless steel for the drinking water installation
Model <i>Modell</i>	IAT 2565
Test Reports <i>Prüfberichte</i>	supplement test: SP 002/14 from 20.01.2014 (TZW) laboratory control test: SP 001/13 from 18.03.2013 (TZW) type testing: SP 005/09-SP 008/09 from 18.06.2009 (TZW) KTW testing: K-228200-13-Ko from 08.04.2013 (WHY) hygienic testing: W-237426k-13-SI from 27.11.2013 (WHY) KTW testing: KA 551/11 from 19.12.2011 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 14453 (01.08.2005) DVGW W 570-2 (01.01.2008) BGA KTW (12.12.1985) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	18.06.2019 / 13-0383-WNV

70028-04-A4-DE

23.05.2014 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
5001570ST	nominal pressure rating: PN 10 nominal diameter: DN 10	
5001755ST; 5001825ST	nominal pressure rating: PN 10 nominal diameter: DN 15	
5001590ST	nominal pressure rating: PN 10 nominal diameter: DN 20	

Type Variation Ausführungsvariante	Explanations Erläuterungen
5001570ST	construction length: 83.5 mm; connection: 3/8"
5001755ST	construction length: 83,0 mm; connection: 1/2"
5001825ST	construction length: 89,0 mm; connection: 1/2"
5001590ST	construction length: 87,0 mm; connection: 3/4"